

## Purchasing Summary

|  |   |  |
|--|---|--|
| <b>EVENT #</b> 6740  | <b>TITLE:</b> Expansion Joints  | <b>COST:</b> \$35,900.00                                     |
| <b>TYPE OF PROCUREMENT:</b> Emergency  | <b>ANNUAL CONTRACT</b> <input type="checkbox"/><br><b>ANNUAL MAINTENANCE AGREEMENT</b> <input type="checkbox"/> | <b>ONE TIME PURCHASE</b> <input checked="" type="checkbox"/> |
| <b>CONTRACT TERM (IF APPLICABLE)</b><br>N/A  |   |  |
| <b>DBE (IF APPLICABLE)</b><br>N/A  |   |  |
| <b>MATRIX (IF APPLICABLE)</b><br>N/A   |   |  |
| <b>NOTES</b>   |   |  |
| <p>Notification of emergency procurement of replacement expansion joints from Engineered Restoration, Inc. in the amount of \$35,900.00. The expansion joints will be used by the President Street Plant to replace the leaking joints located in the motor control center. A motor control center is an assembly to control some or all electric motors in a central location. It consists of multiple enclosed sections having a common power bus and with each section containing a combination starter, which in turn consists of motor starter, fuses or circuit breaker, and power disconnect. The emergency replacement was warranted due to water infiltration, which was causing the motors to fail. Engineered Restorations was selected because it was the first vendor to immediately respond. Delivery: Immediately. Terms: Net 30 days. The vendor was:</p> <p>E.P.     Engineered Restoration, Inc. (Lawrenceville, GA)(D)     \$35,900.00</p> <p>A pre-bid conference was not conducted as this is an emergency purchase. (D) Indicates non-local, non-DBE business. <u>Recommend approval.</u></p> <p>Local Available: No<br/> Total Sent: 1<br/> Total Received: 1<br/> DBE Received: 0<br/> Vendor Federally Debarred/Suspended: No</p> |   |  |