

Purchasing Summary

EVENT # 8310	TITLE: NOTIFICATION OF EMERGENCY PURCHASE	COST: \$29,428.75
TYPE OF PROCUREMENT: Bid	ANNUAL CONTRACT <input checked="" type="checkbox"/> ANNUAL MAINTENANCE AGREEMENT <input type="checkbox"/>	ONE TIME PURCHASE <input type="checkbox"/>
CONTRACT TERM (IF APPLICABLE) N/A		
S/DBE (IF APPLICABLE) N/A		
MATRIX (IF APPLICABLE) N/A		
NOTES		
<p>The Water Reclamation Department conducted an underground conduit repair on Jan 8th to reinstate the plant's intercom system. Unbeknownst to the operator the power line was on top of the conduit that needed to be repaired, which was not shown on the site plans resulting in the operator extracting the power line instead of the intercom conduit. The power line in need of repair, supplies the Wastewater Lab's main power. During the event, sample analysis was ongoing. Therefore, power could not have been suspended without interference and loss of data.</p> <p>In order to safely repair the line and accommodate the power needs for the laboratory without interruption, the job was completed on Sunday, January 10th., by All Electric. Other companies were contacted but were unable to meet the time frame in which the repairs were needed at a cost lower than what was provided by All Electric.</p> <p>In order to avoid future instances, update the site piping plans, and coordinate jobs that will not interfere with sample analysis and main power sources.</p> <p>E.P. All Electric (Savannah, GA) (B) \$29,428.75</p> <p>(B) Indicates local, non-DBE business</p>		