

Purchasing Summary

EVENT #8976	TITLE: Water Leak Repair	COST: \$114,488.00
TYPE OF PROCUREMENT: Emergency	ANNUAL CONTRACT <input type="checkbox"/> ANNUAL MAINTENANCE AGREEMENT <input type="checkbox"/>	ONE TIME PURCHASE <input checked="" type="checkbox"/>
CONTRACT TERM (IF APPLICABLE) N/A		
S/DBE (IF APPLICABLE) N/A		
MATRIX (IF APPLICABLE) N/A		

NOTES

Notification of the emergency procurement for two 550 horsepower Variable Frequency Drives (VFDs) in the amount of \$114,488.000.

The Industrial and Domestic Plant used the VFDs to pump water and potable water to the major industries and the main groundwater system. The two variable frequency drives failed and were inoperable. For normal pumping capacity, all five pumps must be operational for the City's high industrial demand.

The was an emergency purchase because the plant serves as a regional water provider. If the pumps are out of service, the pumping capacity for fire protection, industrial and potable water would be compromised.

E.P. Go Forth Williamson, Inc (Griffin, GA)^(D) \$114,488,000

(D) Indicates non-local, non-DBE business