

Purchasing Summary

EVENT # 7360	TITLE: Switch Repair for substation	COST: \$113,714.29
TYPE OF PROCUREMENT: Sole Source	ANNUAL CONTRACT <input type="checkbox"/> ANNUAL MAINTENANCE AGREEMENT <input type="checkbox"/>	ONE TIME PURCHASE <input checked="" type="checkbox"/>
CONTRACT TERM (IF APPLICABLE) N/A		
S/DBE (IF APPLICABLE) N/A		
MATRIX (IF APPLICABLE) N/A		
NOTES		
<p>Recommend approval to authorize the City Manager to execute a contract with Georgia Power to repair switches at the President Street plant in the amount of \$113,714.29. The switch repairs will be used by the Public Works and Water Resources Department to repair the switches located in the substation at the President Street Plant. Due to the nature/scope of this project regarding high voltage (4160), which is out of the department's purview, a quotation was provided to service the City's side in conjunction with the work to be performed on their side. Performing the work concurrently allows the plant to be removed from utility power once in lieu of rescheduling work for a later date. Work to be performed would include replacement of two 4.16 KV 2000 A switches, replacement of 6-4.16 kV substation lightning arresters, and replacement of 2 runs of 4.16 KV cables, approximately 300 feet total.</p> <p>Delivery: As needed. Terms: Net 30 days. The vendor is:</p> <p>S.S. Georgia Power (Savannah, GA)^B \$113,714.29</p> <p>A pre-bid conference was not conducted as this is a sole source procurement. (B) Indicates local owned business. Recommend approval.</p> <p>Local Available: Yes Total Sent: 1 Total Received: 1 Vendor Federally Debarred/Suspended: No</p>		